



Government Of West Bengal
Office Of The Divisional Fire Officer, Malda
West Bengal Fire & Emergency Services
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo no.: EBFS/P/21/15

Date: 22-05-2023

From:
Divisional Fire Officer, Malda
West Bengal Fire & Emergency Services

To: MOHONI MONDAL WELFARE TRUST
MADIAGHAT, SOVANAGAR, EKBORNA, RATUA, MALDA

Sub: Issuance of Fire Safety Certificate for the occupancy of an existing construction G+2 storied Educational building under group Educationa in the name of style of style of AVIMANYU COLLAGE OF EDUCATION (ADMINISTERED & MANAGED BY MOHINI MANDAL WELFARE TRUST) at the premises no Vill-Madaighat Sovanagar, Mouza-Sultanpur, J.L.No-137, L.R Khatian No-4036, L.R Plot No-40,4211, Post-Ekbirna,, P.S-Ratua, Dist-Malda. Pin-732204.

This is in reference to your application no. 0125189230800031 dated 15-05-2023 regarding the Issuance of Fire Safety Certificate for the occupancy of an existing construction G+2 storied Educational building under group Educationa in the name of style of style of AVIMANYU COLLAGE OF EDUCATION (ADMINISTERED & MANAGED BY MOHINI MANDAL WELFARE TRUST) at the premises no Vill-Madaighat Sovanagar, Mouza-Sultanpur, J.L.No-137, L.R Khatian No-4036, L.R Plot No-40,4211, Post-Ekbirna,, P.S-Ratua, Dist-Malda. Pin-732204.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
3. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.

6. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
7. A Crew of trained fire man should be maintained round the clock for the safety of the building.
8. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
9. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
13. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
14. Fire license to be obtained from this end for the premises (if any) which attracts sec-12 of the fire Services Act.
15. The Fire Safety Certificate is valid for 3(Three) years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629_L Dated-17/04/2018.
16. After three years a certificate is to be obtained from the West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally Signed.
Name: SWAPAN KUMAR DAS
Date: 22-May-2023 14:00:38
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Malda
West Bengal Fire & Emergency Services

Memo No.: EBFS/IP/21/15